51

	Application No.	Applicant(s)
Notice of Allowability	10/662,565	HALE ET AL.
	Examiner	Art Unit
	Vincent Q. Nguyen	2858
The MAILING DATE of this communication appeal all claims being allowable, PROSECUTION ON THE MERITS IS herewith (or previously mailed), a Notice of Allowance (PTOL-85) NOTICE OF ALLOWABILITY IS NOT A GRANT OF PATENT R of the Office or upon petition by the applicant. See 37 CFR 1.313	(OR REMAINS) CLOSED in this a or other appropriate communicati IGHTS. This application is subject	application. If not included ion will be mailed in due course. THIS
1. \boxtimes This communication is responsive to <u>response 3/14/2005</u> .		
2. 🔀 The allowed claim(s) is/are <u>1-13</u> .		
3. 🖾 The drawings filed on 14 March 2005 are accepted by the	Examiner.	
 4. ☐ Acknowledgment is made of a claim for foreign priority una) ☐ All b) ☐ Some* c) ☐ None of the: Certified copies of the priority documents have Certified copies of the priority documents have Copies of the certified copies of the priority do International Bureau (PCT Rule 17.2(a)). * Certified copies not received: 	e been received. e been received in Application No.	
Applicant has THREE MONTHS FROM THE "MAILING DATE"		·
noted below. Failure to timely comply will result in ABANDONN THIS THREE-MONTH PERIOD IS NOT EXTENDABLE.	MENT of this application.	
5. A SUBSTITUTE OATH OR DECLARATION must be subm INFORMAL PATENT APPLICATION (PTO-152) which give		
6. CORRECTED DRAWINGS (as "replacement sheets") mus	st be submitted.	
(a) including changes required by the Notice of Draftspers	son's Patent Drawing Review (PT	O-948) attached
1) 🗌 hereto or 2) 🔲 to Paper No./Mail Date		
(b) including changes required by the attached Examiner' Paper No./Mail Date	s Amendment / Comment or in the	e Office action of
Identifying indicia such as the application number (see 37 CFR 1 each sheet. Replacement sheet(s) should be labeled as such in t		
 DEPOSIT OF and/or INFORMATION about the depo attached Examiner's comment regarding REQUIREMENT 		
Attachment(s) 1. ☐ Notice of References Cited (PTO-892) 2. ☐ Notice of Draftperson's Patent Drawing Review (PTO-948)	6. ☐ Interview Summa Paper No./Mail [Date .
 Information Disclosure Statements (PTO-1449 or PTO/SB/0 Paper No./Mail Date <u>9/15/03 page 2</u> Examiner's Comment Regarding Requirement for Deposit 	<u> </u>	ment of Reasons for Allowance
of Biological Material	9 □ Other	yen 4/15/2005
	VINO	CENT Q. NGUYEN MARY FXAMINER

DETAILED ACTION

Allowable Subject Matter

- 1. Claims 1-13 are allowed.
- 2. The following is an examiner's statement of reasons for allowance:

The prior art of record does not teach or suggest a system of remotely detecting an electric arc event having at least one measuring element for measuring at least one parameter associated with the at least one load and the at least one solid-state switch, wherein said solid-state switch controllably alters the input current to the at least one load according to the at least one parameter, as recited in the independent claim 1; a method of remotely detecting an electric arc having the steps of operating each switch in an on mode wherein each switch permits the input current from flowing to a respective load, and thereafter controlling the input current to the at least one load, determining a condition of each switch and respective load depending upon at least one of the at least one characteristic and the at least one parameter; as recited in the independent claim 6; a system for remotely detecting an electric arc having at least one slave controller disposed proximate, and electrically connected to, the at least one load, wherein the at least one slave controller is capable of measuring at least one parameter associated with the at least one load, and wherein the at least one slave controller is capable of controllably altering the input current to the at least one load, according to the at least one parameter, as recited in the independent claim 9 and in combination of the claims.

Application/Control Number: 10/662,565

Art Unit: 2858

Contact Information

Page 3

3. Any comments considered necessary by applicant must be submitted no later

than the payment of the issue fee and, to avoid processing delays, should preferably

accompany the issue fee. Such submissions should be clearly labeled "Comments on

Statement of Reasons for Allowance."

Any inquiry concerning this communication or earlier communications from the

examiner should be directed to Vincent Q. Nguyen whose telephone number is (571)

272-2234. The examiner can normally be reached on 8:30-5:00.

If attempts to reach the examiner by telephone are unsuccessful, the examiner's

supervisor, Eddie Lefkowitz can be reached on (571) 272-2180. The fax phone number

for the organization where this application or proceeding is assigned is 703-872-9306.

Information regarding the status of an application may be obtained from the

Patent Application Information Retrieval (PAIR) system. Status information for

published applications may be obtained from either Private PAIR or Public PAIR.

Status information for unpublished applications is available through Private PAIR only.

For more information about the PAIR system, see http://pair-direct.uspto.gov. Should

you have questions on access to the Private PAIR system, contact the Electronic


Business Center (EBC) at 866-217-9197 (toll-free).

Vincent Q. Nguyen Primary Examiner Art Unit 2858

April 16, 2005

Title: SYSTEM AND METHOD FOR REMOTELY DETECTING ELECTRIC ARC EVENTS IN A POWER SYSTEM

Inventor(s): Schwarz et al. Atty Dkt No.: 38190/255097 REPLACEMENT SHEET 4/7



Approved V. ngrujen 4/15/2005

FIG. 4.